



USD 320 Wamego-Phase 2-Bid Package 1- Sports Complex Locker Rooms and District Central Kitchen

Addendum 7

Issue Date: 8-2-17

Architect: BBN Architects Inc.

MEP: Orazem & Scalora Engineering, P.A.

Civil Engineer: SMH Consultants

Construction Manager: Coonrod & Associates Construction Co., Inc.

Owner: USD 320 Wamego

The attached documents and / or items below shall hereby become part of the Construction Documents for the referenced project above.

7-1: Reference **Sports Complex Locker Room-Sheet E201-Electrical Details** and ADD note below:

"In lieu of the 300A/2P branch breaker in the MDP, provide a manufacturer's listed 400A lug kit for the existing MDP and provide 2#350,#4G to a 300A/2P NEMA 3R enclosed circuit breaker mounted to MDP equipment rack."