



USD 320 Wamego-Phase 2-Bid Package 2- Multipurpose Building

Addendum 4

Issue Date: 10-2-17

Architect: BBN Architects Inc.

MEP: Orazem & Scalora Engineering, P.A.

Civil Engineer: SMH Consultants

Construction Manager: Coonrod & Associates Construction Co., Inc.

Owner: USD 320 Wamego

The attached documents and / or items below shall hereby become part of the Construction Documents for the referenced project above.

4-1: In specification section 13 34 19- Metal Building Systems- 2.8, D, 1: Revise the paragraph to read: "***Thermal-Resistance Value (R-Value):R19+R11 hr•ft²•deg F/Btu according to ASTM C 518.(R-19 bottom layers, R-11 top layers)***"

4-2: In specification section 13 34 19- Metal Building Systems- 2.8, D, 2: Revise the paragraph to read: "***Must fill purlin cavity.***"